



United States Steel Corporation
Clairton Works
400 State Street
Clairton, PA 15025

May 17, 2004

Dr. Roger C. Westman
Department of Air Quality
Bureau of Air Pollution Control
301 Thirty-Ninth Street
Pittsburgh, PA 15201

U.S. Environmental Protection Agency
Region III
Air, Radiation & Toxics Division
1650 Arch Street
Philadelphia, PA 19103-2029
ATTN: James W. Hagedorn (3AT23)

Assistant Council
Department of Environmental Protection
Southwest Region
400 Waterfront Drive
Pittsburgh, PA 15222-4745
ATTN: Steve Hepler

Department of Justice
Environmental and Natural Resource Division
Environmental Enforcement Section
P.O. Box 7611
Ben Franklin Station
Washington, D.C. 20044
ATTN: David Street, Esq.

Subject: USS Reference Number: 04-0074
ACHD Reference Number: 5164 & 5166
100 & 600 Carbonate Units
USS Clairton Works

Gentlemen:

The attached form confirms our verbal report of the subject incident. This incident was mistakenly reported twice under ACHD Reference Numbers 5164 & 5166. Any questions concerning this matter should be referred to Coleen M. Davis at 233-1015.

Sincerely,

Anton Lukac
Plant Manager
Clairton Works

NOTICE OF OUTAGE OF EQUIPMENT
ARTICLE XXI - SECTION 2108.1

1. USS Reference Number: 04-0074
ACHD Reference Number: 5164 & 5166 This incident was mistakenly reported twice under ACHD Reference Numbers 5164 & 5166.
2. Date & Time of Breakdown: Date: 05/12/04 Time: 1040 hours
3. Company Name: U.S. Steel Corporation - USS Clairton Works
4. Specific Equipment Involved or Affected: 100 & 600 Carbonate Units
5. BAPC Permit Number (if applicable):
6. Location: Clairton, PA
7. Nature and cause of breakdown: During a routine switching of the 100 & 600 Carbonate Units, a pressure relief valve stuck open and coke oven gas was passed through the Sulfur Plant.
8. Identification of Emissions:
 - A. Type(s) (CO, NOX, SO₂, Particulates, Hydrocarbons, etc.)
Intermittent elevated H₂S in the down river gas line system, causing increased SO₂ at point of combustion.
 - B. Toxic qualities of each type (including its qualities as an irritant, and its potential for causing illness, disability, or mortality). SO₂ is an eye, nose, and throat irritant.
 - C. Amount of each type emitted (or likely to be emitted).
Light
9. Measures taken (or to be taken) to minimize length of breakdown and amount of emissions, including shutdown or curtailment (or why it is impossible or impractical to do so).
The 100 Carbonate Unit assumed the work load and the facility resumed operations.
10. Facility back in operation - Date: 05/12/04 Time: 2142 hours

Signature Coleen M. Davis Date 5/18/04
Coleen M. Davis
Senior Environmental Control Engineer Phone: 233-1015